



UKPN STATS SHOWS HV UNDERGROUND CABLES IN THIS SCHEME. REFER TO DIG PACK PRIOR TO INSTALL.

KEY	
	Lantern: Philips Residium FGS224/Libra-PT Tilt: 5° Quantity: 4 Column: 6m Stepped Tubular Steel Lamp: 36W PL-L Control: Telensa
	DTC Lantern Swap Only Lantern: Philips Residium FGS224/Libra-PT Tilt: 5° Quantity: 2 Column: 5m Stepped Tubular Steel Lamp: 36W PL-L Control: Telensa
	Existing Non DTC Lighting Column To Be Removed For Recycling
	Existing Non DTC Lighting Column to be Removed and not Replaced as Annex A Agreed with CCC
	Disconnection of DNO Supply
	Transfer of DNO Supply
	Tree

Design Notes
1. 1-4-1 (Residential) Lighting Design

All lighting column positions marked on site are indicative only

Notes
DIMMING REGIME
• RESIDENTIAL DIM TO 60% BETWEEN 22:00 & 06:00

WARNING - THERE ARE BURIED SERVICES WITHIN THIS SCHEME. REFER TO DIG PACK PRIOR TO REMOVAL / INSTALL AND ENSURE DIG PACK CONTAINS ALL THE INFORMATION
COPYRIGHT RESERVED, BALFOUR BEATTY LIVING PLACES IS THE OWNER OF THE COPYRIGHT SUBSISTING IN THESE DRAWINGS, PLANS, DESIGNS AND SPECIFICATIONS. THEY MUST NOT BE USED, REPRODUCED OR COPIED, IN WHOLE OR IN PART, NOR MAY THE INFORMATION, IDEAS AND CONCEPTS THEREIN CONTAINED (WHICH ARE CONFIDENTIAL TO BALFOUR BEATTY LIVING PLACES) BE DISCLOSED TO ANY PERSON WITHOUT THE PRIOR SPECIFIC WRITTEN CONSENT OF BALFOUR BEATTY LIVING PLACES.

streetlighting

Designer: PT Date of issue: 24/10/14

Checked: DM Authorised: NB Sheet Size: A3 Scale: 1:500 @ A3

Issue: PRELIMINARY Revision: ORIG.

Drawing no.: 7200-1425-V2

Scheme Name and Ward: Cambridge 1425, Cambridge City

Streets on drawing: Red Cross Lane, Milestone 7
Sheet 1 of 1

Schedule Of Existing Columns									
Red Cross Lane	Column		Supply Point	Service Alteration Type	Attachment		Notes	Location	Lamp/Types
	Number	Set back			Type	Alteration Type			
Lighting Column	CC1	BOP	DNO	Transfer to L1SGI	N Watch	Transfer to L1SGI		Junc Hills Road	35W SOX
	CC2	BOP	DNO	Disconnect DNO Supply				o/s no. 18/20	
	CC3	BOP	DNO	DTC Lantern Change Only				opp. no. 8	
	CC4	BOP	DNO	Transfer to L3SGI				opp. Stansgate Avenue	
	CC5	BOP	DNO	Disconnect DNO Supply	N Watch	Transfer to L3SGI		s/o no. 1 Stansgate Avenue	
	CC6	BOP	DNO	Transfer to L4SGI				o/s no. 6	
	CC7	BOP	DNO	DTC Lantern Change Only				opp. Greenlands	
	CC8	BOP	DNO	Transfer to L6SGI	Parking Plate	Transfer to L6SGI		o/s no. 8	

Schedule Of Proposed Columns									
Red Cross Lane	Column		Supply Point	Service Alteration Type	Attachment		Notes	Location	Lamp/Types
	Number	Set back			Type	Alteration Type			
Lighting Column	L1SGI	BOP	DNO	Transfer from CC1	N Watch	Transfer from CC1		Junc Hills Road	36W PL-L
	L2SGI	BOP	DNO	DTC Lantern Change Only				opp. no. 8	
	L3SGI	BOP	DNO	Transfer from CC4				opp. Stansgate Avenue	
	L4SGI	BOP	DNO	Transfer from CC6				o/s no. 6	
	L5SGI	BOP	DNO	DTC Lantern Change Only				opp. Greenlands	
	L6SGI	BOP	DNO	Transfer from CC8	Parking Plate	Transfer from CC8		o/s no. 8	